

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2609 / ५२०११०११-२० - १०

Dated: 11/04/24

It is certified that an inspection team headed by Shri. D.P. Gautam, Assistant Engineer

(Name of Officers with designation) from U.P. Jal Nigam (Rural) PHED Bhauriganj, Amethi U.P.

inspected the D.P.S. Public School, Bhauriganj, Ramganj Amethi U.P.

(Name & Address of the school) on 08/04/24 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 244/2023-24 dated 08/12/2023

of District Level Water Analysis Lab (PHED Lab) certified that

the D.P.S. Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till One year

Signature with Seal:

Name : (D.P. Gautam)

Designation : Assistant Engineer

Name & Address of the Office / Department

सहायक अभियंता, जल निगम
खण्ड कार्यालय उ०प्र० जल निगम
(ग्रामीण), अमेठी
U.P. JAL NIGAM
AMETHI

To

D.P.S. Public School,
Bhauriganj, Ramganj
(Name & Address of the Institution)
Amethi U.P.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Test Report



DISTRICT LEVEL WATER ANALYSIS LABORATORY, UTTAR PRADESH JAL NIGAM(Rural), AMETHI

TC- 10118

Rept No	Test Report/Exe.Eng.Con.Divi./Chemical Test/ 244/2023-24	Issue Date	8/12/2023	Page No. 01
---------	---	------------	-----------	-------------

Customer Details	
Office Name and Address	D.P.S. PUBLIC SCHOOL BHARATGANJ, RAMGANJ-AMETHI
Ref Letter No & Date	22/2023

District	Amethi	Block	Bhadar
Gram Panchayat	Ramganj	Village	Ramganj
Habitation	Ramganj	Location	
Water Source	R.O.	Sample Code	A/8/12/2023
Quantity of Sample	1.0 Litter	Date of Sample Collection	8/12/2023
Receiving Date:	8/12/2023	Sample Collector	Sharad Prakash Singh
Sample Depositer	Sharad Prakash Singh	Sampling Method Used.	
Analysis Start Date	8/12/2023	Analysis Completion Date	8/12/2023

Environmental Condition		Analysis Completion Date		8/12/2023
Temperature	25±3 oC	Humidity	50±15%	

Technical Data of Analysis

S. No.	Parameter	Units	Observed Value	Specified Values as per		Ref. Method of Analysis
				Acceptable limit	Permissible Limit	
1	2	3	4	5	6	7
1	Turbidity *	(NTU)	0	1.00	5.00	IS 3025 (Part 10) : 2017
2	pH Value *	(mg/L)	7.56	6.5-8.5	6.5-8.6	IS 3025 (Part 11) : 2022 (Electrometric Method)
3	TDS *	(mg/L)	180	500.00	2000	IS 3025 (Part 16) : 2012
4	Fluoride *	(mg/L)	0.64	1.00	1.5	IS 3025 (Part 60) : 2008 (Electro. Chem. Prob Meth)
5	Chloride *	(mg/L)	113.6	250.00	1000	IS 3025 (Part 32) : 2014
6	Iron *(as Fe)	(mg/L)	0	0.30	1	APHA 23rd Edition-3500-Fe Method B(Phenanthroline:2017)
7	Sulphate *(as SO4)	(mg/L)	14.56	200.00	400	APHA 23rd Edition-4500-SO4 Method E(Turbidity Method:2017)
8	Nitrate *(as NO3)	(mg/L)	7.58	45.00	45	APHA 23rd Edition-4500-NO3 Method B(UV-Screening Method):
9	Total Alkalinity*(as CaCO3)	(mg/L)	140	200.00	600	IS 3025 (Part 23) : 2019
10	Total Hardness *(as CaCO3)	(mg/L)	80	200.00	600	IS 3025 (Part 21) : 2019
11	Calcium *	(mg/L)	16.032	75.00	200	IS 3025 (Part 40) : 2019
12	Magnesium*	(mg/L)	9.6	30.00	100	IS 3025 (Part 46) : 2019
13	Taste *	Qualitative	Agreeable	-	-	IS 3025 (Part 08) : 2017
14	Odour *	Qualitative	Agreeable	-	-	IS 3025 (Part 05) : 2018
15	Colour *	Hazen	0	5	15	IS 3025 (Part 04) : 2021

- Note: 1)*indicates parameters that are NABL accredited.
2)This test results related to the sample tested above
3)The report shall not to be reproduced in full without approval of authority
4)This is the end of the report

Neha Maurya

Prepared By
Neha Maurya
(Deputy Technical Manager)

Chandra Prakash Sharma

Authorised signatory
Chandra Prakash Sharma (Technical Manager)

Laboratory Contact Details :- Name :- Chandra Prakash Sharma
Mo.No.- 9628474106